LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 04/13/2021 -2022

Property Owner: Kevin & Shirin Lamp

Mailing Address: 27407 Yaak River Rd Troy, MT 59935

Telephone: (Home) (Work)

Name of Person Who Installed System Being Reviewed: Keith Mack

Type of System Work Reviewed:

___ New Installation __XX__ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 65' laterals.

Property Description:

Legal: GOLD DUST, S04, T35 N, R32 W, ACRES 6.331, LOTS 1-3 PM 7006

Address or Location: 27407 Yaak River Rd Troy, MT 59935

Reviewed Design Components:

Wastewater Flows: 130/day Sewer Lines: Septic Tank: 1000 Gallons EffluentFilter:

Dosing or Lift Tank: NO Drainfield: 130 Lineal Feet Drainfield Construction: drain/wash rock

Hydraulic Function: yes

Comments:

System Review Documentation Statement:

I, Keith Mack *, have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.*

Signed: Keith Mack *Date:* 4-16-21

Title: _____

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.

DISCLAIMER

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

LOT LAYOUT

