LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/03/2021 Expiration Date: 06/03/2022

Property Owner: Josh Letcher c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Gideon Yutzy License No. 113

___XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 84' pressure dosed laterals in 3' wide trenches.

Parcel Description:

Legal: S11, T36 N, R27 W, C.O.S. 4502, PARCEL A, ACRES 1

Address or Location: 1844 MILLS SPRING RD Eureka, MT 59917

Geo/Assessors code: 0000054993

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 334 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Gideon Yutzy, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Gideon Yutzy *Date:* 12-2-2021

Title: Licensed Installer L.I. # 113

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

