LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/07/2021 Expiration Date: 07/07/2022

Property Owner: Lincoln County c/o: Marc McCully

Address: 512 California Ave Libby, MT 59923

Telephone: (Home) (Work)

Installer: TCI License No.

____ New Installation ____ Existing System

____ Repair __XX__ Replacement ____ Extension ____ Other

Describe: Installing 2 Ring Dry Well & New Tank .

Parcel Description:

Legal: S34, T31 N, R31 W, TR 2E IN SWSWNW 2.549 ACRES

Address or Location: 674 COUNTY SHOP RD Libby, MT 59923

Geo/Assessors code: 0000011365

Approved Design Criteria:

Bedrooms: Septic Tank Size: 1000 gallons Drainfield Size: Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Levi Thomas *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 8/15/21


Title: VP of TCI

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



1000 gallon tank
1 drywell, 2 high

N