

**LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 08/16/2021

Expiration Date: 08/16/2022

Property Owner: Willaim & Debra Llewellyn

c/o:

Address: [REDACTED]

Telephone: [REDACTED] (Home)

(Work)

Installer: Mountain Contracting

License No. 3

☒ XX New Installation ☐ Existing System
☐ Repair ☐ Replacement ☐ Extension ☐ Other

Describe: Three 80' laterals.

Parcel Description:

Legal: ELK MEADOWS UNIT 2, S15, T37 N, R27 W, Lot 1D, ACRES 5, PM 5832A

Address or Location: LOT 1D

Geo/Assessors code: 0000017876

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 240 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi Hooper, R.S.*

Closure Statement:

I, Richard Luciano have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: *[Signature]* Date: *9/16/2021*


Title: *Ins. Teller*

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



10t / D Hewellyn Home

Elk Meadows

as per
COS

DO TO PROPERTY LINE

Replacement
Area

3 Bedroom
House

#4 95' per line

4" Drain pipe w/ 6" Drain flange
Covered with
Brown paper
Top & Bottom

4" End caps

30'
4" Sch 40

Standard
D. Box
4 outlets

3 @ 80' laterals
45° Angle's on Drain runs

Clear
out

1000
gal.
Tank

Well

110'

Drive way

North