County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/29/2021 Expiration Date: 04/29/2022

Property Owner: Georgia McGhee c/o:

Address: 655 Flower Creek Rd Libby, MT 59923

Telephone: (Home) (Work)

Installer: Tally Hoe License No. 1

___ New Installation ___ Existing System

____ Repair __XX__ Replacement ___XX_ Extension ____ Other

Describe: Replace metal tank with concrete add more dry well.

Parcel Description:

Legal: S09, T30 N, R31 W, TRACT 2D1D IN SE4SE4 1.820 ACRES

Address or Location: 655 Flower Creek Road Libby, MT 59923

Geo/Assessors code: 0000008542

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 2 dry wells Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Thomas J Cole *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 5-28-21


Title: owner operated

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Flower Ck
100'
1 Bed
New well
New tank
old dry well
old tank
1 Bed
well
?
well
Flower Ck Rd
N