PERMIT

Issue Date: 06/18/96 Expiration Date: 06/19/97

Property Owner: Danene L. McNamara c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: Owner w/ Don Rossbans Help License No. _____

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: S21 & 28 T35 R26

Address or Location: Lot 32 of Barbaby Lakes Properties Unit 2

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 200 lineal feet

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: *ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.*

Issued By: *Kendra J. Lind, R.S.*


Closure Statement:

I, KENDRA LIND, evaluated by phone ~~have inspected~~ this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: SANITARIAN

LOT LAYOUT


TERNING DR EAST
VIEW 'A'
STANDARD 4" DRAIN FIELD PIPE
2.8"
24"
THERE IS 6" OF WASHED DRAIN ROCK BELOW PIPE
10" TO EACH SIDE OF PIPE
2" MIN OF ROCK ON TOP
MIN OF 12" SOIL ON TOP OF ROCK
ROCK COVERED WITH LAYER OF PAPER
721.66'
713.99'
PROPOSED DRAIN FIELD REPLACEMENT AREA
APPROX 200' FROM PROP LINE
SEE VIEW A FOR SEPTIC DRAIN FIELD DESIGN
"D" BOX
100'
10'
10'
HOUSE SITE
40'
FROSTLESS FAUCET
SEPTIC TANK 1000 gal
ROCKY SOIL
LEVEL GROUND
DOWN SLOPE
FUTURE GARAGE SITE
DISTANCE TO POND 250'
WATER MAIN FOR SUB DIVISION
BARNABY LK RD
DRIVEWAY
118.27'
554.19'
EXISTING POND
(NO INLET OR OUTLET)
NOTE: ① NO RESTRICTIONS FROM PROPERTIES COVENANTS
② NO UNDERGROUND CABLES