LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Sign & return

Issue Date: 09/07/2021 (reissue of 6/15/20 permit) Expiration Date: 09/06/2022

Property Owner: Shawn Merritt c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Elmer Brenneman License No. 170

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other _____

Describe: Four 84' laterals using chambers

Parcel Description:

Legal: TR 2D in NWNE & NENW or Parcel A of CS 2004 26.848 Acres split fr #7788

Address or Location: Parcel A

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 336 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

Closure Statement:

I, Elmer Brenneman *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed Elmer Brenneman *Date:* 10-25-2021

Title: Brenneman Excavation

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

RECEIVED
NOV 09 2021
BY

LOT LAYOUT

