installer

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/20/2021 Expiration Date: 09/19/2022

Property Owner: Kip Metcalf c/o: Enviro-Tech Consulting, Inc

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: David Hall License No. 169

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other _____

Describe: Gravity fed system with 3 laterals

Parcel Description:

Legal: Assessment #12027

Address or Location: S17 T35N R26W, NENW, 40 Acres

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 250 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

Closure Statement:

I, David Hall *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: David Hall *Date:* 9-19-22

Title: licensed installer

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

Legend

- ⊠ test hole
- ≡ proposed drainfield site
- ▭ proposed replacement area
- Ⓐ existing well site w/ 100' isolation zone
- ▱ mixing zone
- ⊠ proposed septic tank

Name: Metcalf
County: Lincoln
Location: NENW ¼
sec.17-T35N-R26W

Note- there is no COS &
no meets & bounds to this property
as per Clerk & recorder



Enviro-Tech
Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795