# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/01/2021 Expiration Date: 08/31/2022

Property Owner: Arlyn Moots & Rita L. Clarke-Moots c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: self License No.

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other _____

Describe:

*Parcel Description:*

Legal: S21 T33 R34

Address or Location: Whitetail Acres, Lot 3

*Approved Design Criteria:*

# Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 200 lineal feet

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** *Kathi J. Hooper, R.S.*

Closure Statement:

*I,* Levi Thompson *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*


*Signed:* _____ *Date:* 9/9/21

*Title:* Vice President

RECEIVED
SEP 09 2021
BY:

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-283-2442**


LOT 3#
3 ACRES
18'