LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/27/2021 Expiration Date: 07/27/2022

Property Owner: Edward Muehlberger c/o: Craig & Sharon Johnson

Address:

Telephone: (Home) (Work)

Installer: License No.

___XX___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 75' laterals using chambers.

Parcel Description:

Legal: RMR, S29, T31 N, R33 W, ACRES 1.37, LOT 1C PM 6662

Address or Location: LOT 1C

Geo/Assessors code: 0000052540

Approved Design Criteria:

Bedrooms: 1 Septic Tank Size: 1200 gallons Drainfield Size: 300 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Dustin Welch, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 9-23-21

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

RECEIVED
OCT 04 2021
BY:

LINCOLN COUNTY, MONTANA

LOT LAYOUT

LOT 1C OF THE AMENDED RMR SUBDIVISION PER PLAT NO. 6662 IN THE NE 1/4 OF SECTION 29, TWP. 31 N., R. 33 W., P.M.M.


FOR: Edward Muehlberger

Date: JULY 2021
EQ# 21-2059


LEGEND

- PROPOSED DRANIFIELD 2-24" X 75' TRENCHES 7' APART
- PROPOSED REPLACEMENT DRAINFIELD 2-24" X 75' TRENCHES 7' APART
- TP — SOIL PROFILE
- PT — PERCOLATION SITE
- W — WELL
- SLOPE

STANDARD ABSORPTION TRENCHES
GRAVITY FED
DETAIL OF POND & SWALE



SLOPES



NOTES:
-LANDOWNER IS RESPONSIBLE FOR MAINTAINING STORMWATER STRUCTURES.
-EXISTING 1 BEDROOM HOME: 150 GAL/DAY
-PERC RATE: 11 MIN/INCH
-APPLICATION RATE: 0.5
-150 SQ.FT. ABSORPTION TRENCHS

SCALE
100 0 100
1 inch = 100 ft.

Davis Surveying Inc.
TROY MONTANA, (406) 295-5441

DATE: 07/19/2021	
DRAWN BY: CJR/KD	FILE: MUEHLBERGER SEPTIC