SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 7-14-75

Phone [redacted]

Property Owner Jean Overton Address [redacted]


Lot, Block Number, or legal description of Property Lake Creek - Iron Creek junction

To be built by: Lyman Hall Square feet absorption area. 180 sq ft.


Septic Tank Size 750 gal # of bedrooms 2 Water Supply Well -

Description of Absorption Area: Dig a ditch 90' in length x 2½-3' deep x 2' wide according to lot layout and ditch diagram — Keep pipe fairly level - about ½ bubble drop in each 10' length

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



ditch diagram



Soil: gravel

Issued by Ron Radus Inspected by _____

Date 7-14-75