LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/16/11 Expiration Date: 12/17/12

Property Owner: Rick Peterson c/o: Koocanusa Excavating

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Koocanusa Excavating License No. 135

____ New Installation __XX__ Existing System

_____ Repair __XX__ Replacement_____ Extension _____ Other

Describe: Using gravelless chambers – sizing reduction allowed per "Drainfield Size" below.

Parcel Description:

Legal: S12 T36 R26

Address or Location: 1493 Mill Springs Loop

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 144 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

REVISIONS			
REV	DESCRIPTION	BY/DATE	APPD/DATE



INSTALLED 11-15-11

RICK PETERSON SEPTIC

REV	DATE	COMPANY	SCALE:	ENGINEER / SURVEYOR	KOOCANUSA EXCAVATING
		KEI	1/16 = 1'-0"		PETERSON PROJECT
		CONTRACT:	DATE:	DWG FILENAME:	SEPTIC LAYOUT
		VERSAL	3/28/96		DRAWN: 11/15/11
		PLOT FILE:	WEIGHT:		R. PETERSON 11/15/11
		PAL-0001			JOB NO. 06111-001 SHEET NO. 1

⑥ ⑤ ④ ③ ②