

**LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 08/16/2021

Expiration Date: 08/16/2022

Property Owner: Darwin D Pluid

c/o:

Address: [REDACTED]

Telephone: [REDACTED] (Home)

(Work)

Installer: Earth Works

License No. 164

☒ **XX** New Installation ☐ Existing System
☐ Repair ☐ Replacement ☐ Extension ☐ Other

Describe: Two 40' laterals 3' wide gravelless w/25% reduction.

Parcel Description:

Legal: VELVET GROVE 5, S23, T37 N, R27 W, ACRES 5.03, LOT 14 PM 7218

Address or Location: LOT 14

Geo/Assessors code: 0000059883

Approved Design Criteria:

Bedrooms: 1 Septic Tank Size: 1000/500 gallons Drainfield Size: 80 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi Hooper, R.S.*

Closure Statement:

I, Marcia Davis, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Marcia Davis

Date: 8/10/22

Title: Envir. Health Tech.

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly
for a prescribed period of time.

15 app Rate
 25% Grassless Reduction
 $\frac{150}{15} = 300 \div 3 \text{ (3000 infiltrators)} = 100$
 $100 \times .25 \text{ (reduction)} = 75$
 2 40 ft lats

