LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/29/2021 Expiration Date: 09/29/2022 Updated

Property Owner: Michael Scheel c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Chuck Riley License No. 147

___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension __xx__ Other- Renewal (MD)

Describe: REVISED (5-25-22) four laterals at 72', infiltrators.

Parcel Description:

Legal: S33 T31 R31

Address or Location: Parcel B1 CS 3588

Geo/Assessors code: 0000050054

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 288 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jesse Haag

Closure Statement:

I, Charles V Rily, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Charles V Rily *Date:* 6-1-22

Title: owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

72
72
72
72
Dwelling