LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/12/2021 Expiration Date: 04/12/2022

Property Owner: Sivertson Family Trust c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Welch Excavating License No. 155

___XX___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 86' laterals.

Parcel Description:

Legal: LASALA, S27, T32 N, R34 W, ACRES 2.0985, LOT 5 PM 6025

Address or Location: LOT 5 275 LaSala Dr Troy, MT 59935

Geo/Assessors code: 0000013565

Approved Design Criteria:

Bedrooms: 4 Septic Tank Size: 1500 gallons Drainfield Size: 258 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Dustin Welch, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 5-5-21

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY MONTANA

SITE SKETCH

LOT 5 OF THE LASALA SUBDIVISION PLAT NO. 6025
S1/2 Section 27 Twp. 32 N., R. 34 W., P.M.M.
For: Sivertson Date: December 2020


NOTE:


SPOT ELEVATIONS SHOWN HEREON ARE BASED ON AN ASSUMED ELEVATION OF 1869' ON THE SOUTHEAST CORNER OF LOT 5

Graphic Scale:

100 0 50 100

(1 inch = 100 ft.)





DAVIS SURVEYING INC.

TROY, MONTANA

DATE: 12/8/20	REV:
DRAWN BY: CJR	
Land Projects 2020	
FILE: T323427B.dwg	

LEGEND

◉	FOUND A 5/8 INCH DIA. REBAR WITH A 1 1/4 INCH DIA. PLASTIC CAP STAMPED K.E.D. 4975-S
○	COMPUTED POINT
×1867.29	SPOT ELEVATIONS