County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/23/2020 Expiration Date: 10/23/2021

Property Owner: ~~Ron Langley~~ Carolyne Story c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Tally Hoe License No. 1

___ New Installation __XX__ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 80' Laterals using chambers.

Parcel Description:

Legal:

Address or Location: 80 Parmenter Dr Libby, MT 59923 (90 Parmenter Dr is the old address)

Geo/Assessors code:

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 160 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Thomas J Cole, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 10-25-20

Title: owner operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

ISSUED TO: Ron Langley PHONE: 293-7603

ADDRESS: 90 Parmenter Drive Libby CONTRACTOR:

ISSUED BY (sign.): John Peterson, RS DATE: 6-12-92

INSPECTION BY (sign.) DATE:

*PLEASE NOTE: The Lincoln County "On-site Sewage Disposal Regulation" does not conform with all requirements of the Montana State "Sanitation in Subdivision Act". Therefore, septic systems permitted under the county regulation may not be approvable for the purpose of future land division health reviews.

You must notify the Department of Environmental Health a minimum of 8 working hours before backfilling the septic system, so that it can be inspected.

LOCATION OF PROPOSED SYSTEM: 90 Parmenter Drive Lot 24 Glenwood Homes

Proposed
SEPTIC TANK: 1000 gal. ABSORPTION AREA: 320 ft²

SEWAGE DISCHARGE: ~ gal/day No. OF BEDROOMS: 2

WATER SUPPLY SOURCE: City SOIL: Silty loam SLOPE: 0%

Drainfield
INSTRUCTIONS: Dig a ditch 100' long x 2½-3' deep x 2' wide according to lot layout & Septic system regulation. Slope of pipe should not exceed a 1% drop.

SKETCH OF LOT LAYOUT:

