LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/24/2021 Expiration Date: 11/24/2022

Property Owner: Sweeley, Jim and Tanya c/o:

Address: [redacted]

Telephone: [redacted] (Work)

Installer: Kent Hayes / K&D Hayes Dirtworks License No. 144

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other- Renewal (MD)

Describe: Gravity system with 1,000 gallon tank and 2 laterals @ 100-feet each

Parcel Description:

Legal: NORTHERN EXPOSURE, S18, T36 N, R27 W, ACRES 2.509, LOT 1 PM 6577

Address or Location: 194 Timber Trail Rd.

Geo/Assessors code: 0000005512

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1,000 gallons Drainfield Size: 200 Lineal Feet

Special Instructions: Laterals to be spaced by at least 5-feet from trench wall to trench wall. For this permit to be considered valid, the installer must provide signed closure statement.

INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi Hooper, R.S.

Closure Statement:

I, M. Kent Hayes, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: M. Kent Hayes *Date:* 12-10-2021

Title: ~~Oper.~~ Owner Operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.