LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/19/2021 Expiration Date: 05/19/2022

Property Owner: Roy Tanner c/o:

Address: 6949 Kootenai River Rd Libby, MT 59923

Telephone: [redacted] (Home) (Work)

Installer: Owner License No.

___XX___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: ~~Two 82'~~ THREE 56' laterals using chambers.

Parcel Description:

Legal: BIG HORN TERRACE, S14, T31 N, R32 W, ACRES 1.041, LOT 6

Address or Location: LOT 6 -6949 Kootenai River Rd Libby, MT 59923

Geo/Assessors code: 0000002482

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000/500 gallons Drainfield Size: 164 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, JAKE MERTES *, have inspected this system and found it to be in compliance with the conditions of the permit, and the ~~Lincoln~~ County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 7/7/2021

Title: COUNTY SANITARIAN

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

: SURVEY
division
orth,

021

observation)
State Plane 83
et)

D 2×82'
NT 2×82'

