LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 30/10/2022 Expiration Date: 03/10/2023

Property Owner: Workman, Brad c/o: Bradley Persson

Address: [redacted]

Telephone: [redacted]

Installer: Bradley Persson License No. 159

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Pressure-dosed system with 1,500 gallon septic tank, 500 gallon pump tank/chamber, ME-45 pump and effluent filter. Gravelless trenches (infiltrators) with 4 laterals @ 64-feet each in length.

Parcel Description:

Legal: EUREKA HILLS PH 1, S26, T36 N, R27 W, ACRES 2.479, LOT 5 PM 6823

Address or Location: 77 Elmhurst Way, Eureka, MT 59917

Geo/Assessors code: 0000054960

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1,500 gal tank / 500 gal pump tank Drainfield Size: 256 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Closure Statement:

I, Brad Persson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 5-9-22

Title: Installer Lic # 159

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.
406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

