LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/05/2021 Expiration Date: 10/05/2022

Property Owner: Gideon Yutzy c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Elmer Brenneman (Brenneman's Excavation License No.: 170

Proposed Work: (Check One) XXX New Installation ___ Existing System

___ Repair ___ Replacement ___ Extension ___ Other

Describe:

Parcel Description:

Legal: Green Basin Views: S14, T37N, R28W

Address or Location: 6116 West Kootenai Rd., Rexford, MT 59930

Assessment Code: 0000010666

Approved Design Criteria: 1000-gallon tand and 2 70' laterals

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 140 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Dustin Webb, RS

Closure Statement:

I, Elmer Brenneman, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Elmer Brenneman *Date:* 11-01-2021

Title: Brennemans Excavation.

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

