LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/14/2020 Expiration Date: 08/14/2021

Property Owner: Arnold Brouillette c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work) [redacted]

Installer: Bradley Persson License No. 159

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 75' Laterals using chambers.

Parcel Description:

Legal: ROLLING MEADOWS UNIT 2, S27, T37 N, R27 W, Lot 005, PM #5230

Address or Location: LOT 5

Geo/Assessors code: 0000013944

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 150 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Bradley S. Persson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* Sept 24-2020


Title: Installer / Licence # 159

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

LOT LAYOUT


N
Gravel Side Road
R Zone
0 Lot
0-75' Lines
TANK
House
Drive to
Airport Road
Well