LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/27/2020 Expiration Date: 10/27/2021

Property Owner: Ian Caswell c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work) 406-291-2959

Installer: Miller Excavating LLC License No. 52

____ New Installation ____ Existing System

____ Repair ____ Replacement __XX__ Extension ____ Other

Describe: Adding 70' ft to an existing 140'Ft

Parcel Description:

Legal: S09, T37 N, R28 W, C.O.S. CS #3139, PARCEL B, 12.239 ACRES

Address or Location: 390 Rocky Mountain Trail Rexford, MT 59930

Geo/Assessors code: 0000012632

Approved Design Criteria:

Bedrooms: 4 Septic Tank Size: 1000 gallons Drainfield Size: 210 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Kaufman PL

59 T

