LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/19/2020 Expiration Date: 11/19/2021

Property Owner: Rodney & Denise Forsness c/o: Brad Persson

Address: [redacted]

Telephone: [redacted] (Home) (Work) [redacted]

Installer: Rodney Forsness License No. 159

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 50' Lines of 2' infiltrators.

Parcel Description:

Legal: S25, T36 N, R26 W, C.O.S. 1996, PARCEL A, ACRES 19.892, or N2NWNE

Address or Location: 620 Sherman Creek Place Eureka, MT 59917

Geo/Assessors code: 0000053822

Approved Design Criteria:

Bedrooms 1 Septic Tank Size: 1000 gallons Drainfield Size: 100 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Bradley S. Persson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 6-7-2021

Title: inspected & signed off License #159

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

S25, T36N, R26W
N½ NW¼ NE¼

LOT LAYOUT

PROPERTY OWNER
RODNEY + DENISE FORSNESS
620 SHERMAN CREEK PLACE
ASSESSOR # 53822



WELL IS 150 FEET NORTH OF PLANNED 1 BATHROOM SEPTIC FOR THE SHOP/ GARAGE.