LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/17/2020 Expiration Date: 12/17/2021

Property Owner: Rebecca Jandasek c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: M Kent Hayes License No. 044

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 85' X 3' trenches. Pressure dosed system.

Parcel Description:

Legal: ELK VIEW, S28, T35 N, R26 W, ACRES 1.68, LOT 1 PM 6840

Address or Location: 3183 MEADOW CREEK RD FORTINE, MT 59918

Geo/Assessors code: 0000014302

Approved Design Criteria:

Bedrooms: 1 Septic Tank Size: 500-1000 gallons Drainfield Size: 255 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, M. Kent Hayes, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: M. Kent Hayes *Date:* 6-5-2021

Title: Installer License NO: 144

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

ELK VIEW
S 28 T 35 N R 26 W

EQ #07-1158
APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Barbara Kingery 6/7/07
Reviewer Date

