LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/01/2020 Expiration Date: 09/01/2021

Property Owner: Jeffrey Kalwara c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Bob Cuffe License No. 141

__XX__ New Installation ____ Existing System

____ Repair ___ Replacement ____ Extension ____ Other

Describe: Three 85' Laterals using drain rock system.

Parcel Description:

Legal: MEADOW CREEK ESTATES, S28, T35 N, R26 W, Lot 1, ACRES 6, PM 6992

Address or Location: 3375 MEADOW CREEK RD Fortine, MT 59918

Geo/Assessors code: 0000014337

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000/1500 gallons Drainfield Size: 255 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Robert Cuffe, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 11/6/20

Title: President, Glacier Excavating, Inc

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Lot 1 Meadow Creek Estates
Kalwara Residence Plat

Scale : 1"= 40'

