LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/04/2020 Expiration Date: 06/04/2021

Property Owner: Kevin Kazan c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Kootenai Sand & Gravel Inc License No. 109

__ New Installation __X__ Existing System

____ Repair __X__ Replacement ____ Extension ____ Other

Describe: Four 94' Pressure dosed laterals in 3' wide trenches

Parcel Description:

Legal: S26, T36 N, R26 W, TR-2C IN NESE 32.67 ACRES

Address or Location: 19 Haven Bend Eureka, MT 59917

Geo/Assessors code: 0000007164

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 2- 1000 gallons Drainfield Size: 376 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Donavan Truman, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 7/23/2020

Title: Licensed Installer 109 Kootenai Sand & Gravel, Inc

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

N

VMK Enterprises

The pressure distribution 1½"-160 pvc pipe w/ 3/16-inch orifices on 5' spacing.

Drainfield is 4-94' pressure dose laterals in 3' wide trenches.

