LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/27/2020 Expiration Date: 10/27/2021

Property Owner: Gregory Keiper c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work) 406-293-1501

Installer: Logan Munts License No. 160

___ New Installation ____ Existing System

__XX__ Repair __X X__ Replacement ____ Extension ____ Other

Describe: Install 3 ring drywells with drain rock.

Parcel Description:

Legal: WOODWAY PARK 1ST ADDN, S05, T30 N, R31 W, BLOCK 3, ACRES 0.2391, LOT 6

Address or Location: 195 Norman Ave Libby, MT 59923

Geo/Assessors code: 0000008038

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 3X1 Drywells

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Logan Munts *, have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 10/28/20

Title: Sawtooth Excavating LLC

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Street

LOT LAYOUT



Street

Road