LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/01/2025(Renewal) 09/27/2023 Expiration Date: 06/30/2026 Permit# 25-11129

Property Owner: Braden Lowry

Mailing Address: [redacted]

Installer: Dustin Welch License #: 115

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity septic system.

Parcel Description:

Legal: WILDERNESS PLATEAU, S19, T31 N, R33 W, BLOCK 003, LOT 31, ACRES 0.784

Property Address: Snowshoe Lane. Troy, MT 59935 Assessment Code: 11129

DEQ COSA: EQ#27-85-S23-429 Date: 11/30/84

Approved Design Criteria: Installation of new gravity septic system with 2 laterals @ 65' with a minimum of 5' between trenches.

# of Bedrooms: 2 Septic Tank Size: 1000 Trench Width: 24"

# of Laterals: 2 Length of Laterals: 65' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 7/1/25

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



Yard has been leveled Flat so ditch height will not be an issue virgin grand Remaine Untouched with grass Still on it until date of digging

measurements are Approximate