LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 12/14/2020

2021

Property Owner: Barbara Marshall

Mailing Address: [redacted]

Telephone: [redacted] (Home) (Work)

Name of Person Who Installed System Being Reviewed: Koocanusa Plumbing

Type of System Work Reviewed:

__XX__ New Installation __XX__ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 60' lines with perf pipe and drain rock.

Property Description:

Legal: S07, T36 N, R27 W, C.O.S. CS #3151, PARCEL B, IN SEC 6-7 CS 3151

Address or Location: 690 Ponderosa Pine Drive Eureka, MT 59917

Reviewed Design Components:

Wastewater Flows: 225/day Sewer Lines: SCHED 40 Septic Tank: 1000 Gallons EffluentFilter: UNK

Dosing or Lift Tank: NO Drainfield: 180 Lineal Feet Drainfield Construction: Drain Rock & Perf Pipe

Hydraulic Function: YES

Comments: Adding one 60' lateral to unpermitted system to become compliant.

System Review Documentation Statement:

I, _____, have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.

Signed: _____ *Date:* 5-25-21

Title: owner

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.

DISCLAIMER

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

LOT LAYOUT

