LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/14/2020 Expiration Date: 09/14/2021

Property Owner: Teri Noble c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Noble License No. 20

___XX___ New Installation ___ Existing System

___ Repair ___ Replacement ___ Extension ___ Other

Describe: Three 85' Laterals using chambers.

Parcel Description:

Legal: MBMI DEVELOPMENT INC, S25, T31 N, R31 W, ACRES 2.452, LOT 4A CS 4397

Address or Location: LOT 4A

Geo/Assessors code: 0000050469

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 300 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Chris Noble *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 9-18-2020

Title: President

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

LOT 4 - MBMI DEVELOPMENT SUBDIVISION
PLAT #7152





40 0 80

FOR OPTIMAL CLARITY REPRODUCE IN COLOR