LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/14/2020 Expiration Date: 12/14/2021

Property Owner: Cloyd Peterson c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Koocanusa Excavating License No. 135

___ New Installation __XX__ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Adding new 1000/500 septic tank to pump effluent from new tank to existing tank.

Parcel Description:

Legal: S03, T36 N, R27 W, C.O.S. 3489, PARCEL B, ACRES 9.88

Address or Location: 141 Truss Rd Eureka, MT 59917

Geo/Assessors code: 0000007123

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 180 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Buck Schermerhorn, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 2/5/21

Title: President

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

REV	DESCRIPTION	BY/DATE	APRD/DATE





CLOYD PETERSON 141 TRUSS ROAD
EUREKA, MT 59917

THIS DRAWING IS PROPERTY OF KEI LINES. CONTRACT HAS BEEN SECURED BETWEEN OWNER & KEI IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM KEI MANAGEMENT

REV	DATE	COMPANY	SCALE:	KOOCANUSA EXCAVATING
		KEI	1/10 & NOTED	PETERSON SEPTIC
		CONTRACT:	DATE:	SITE LAYOUT
		VERBAL	12/20	12/7/20
		PLOT FILE:	WEIGHT	C. PETERSON 12/7/20
		PML-0001		CLOYD-002 1