**LINCOLN COUNTY**
**DEPARTMENT OF ENVIRONMENTAL HEALTH**
**AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT**

Issue Date: 10/08/2020

Property Owner: Barry Roose

Mailing Address: [redacted]

Telephone: [redacted] (Home) (Work)

Name of Person Who Installed System Being Reviewed: Unknown

Type of System Work Reviewed:

___ New Installation __XX__ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 4" Pipe each 44' Long.

*Property Description*:

Legal: S03, T35 N, R26 W, C.O.S. 4594, PARCEL D, ACRES 70.92, IN SEC 3 & 4

Address or Location: 5233 US HIGHWAY 93 S EUREKA, MT 59917

Reviewed Design Components:

Wastewater Flows: 240 Sewer Lines: Septic Tank: 1200 Gallons Effluent

Filter:Dosing or Lift Tank: Drainfield Size: 176' Lineal Ft Drainfield Construction: Drainrock

Hydraulic Function: yes

Comments:

System Review Documentation Statement:

*I, _____, have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.*

*Signed:* _____ *Date:* _____

*Title:* _____

**NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.**

***DISCLAIMER***

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

# LOT LAYOUT

