LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 02/10/2021 Expiration Date: 02/10/2022 Renewal

Property Owner: David L Yutzy c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Brenneman's Excavation License No.

___XX___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 70' X 2 trenches using infiltrators.

Parcel Description:

Legal: S25, T36 N, R27 W, C.O.S. 3835, ACRES 0.882, TR 1DB COS 3035

Address or Location: 1812 TOBACCO RD EUREKA, MT 59917

Geo/Assessors code: 0000055874

Approved Design Criteria:

Bedrooms: 2 (3 bedroom system) Septic Tank Size: 1000 gallons Drainfield Size: 210 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Elmer Brenneman *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Elmer Brenneman *Date:* 4-10-2021

Title: Brenneman's Excavation

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

1812 Tobacco Rd

