LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/27/2020 Expiration Date: 05/27/2021

Property Owner: Thomas Beilstein c/o: Billie Gardner

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Owner License No.

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 75' Laterals using chambers

Parcel Description:

Legal: WOLF MEADOWS, S11, T29 N, R31 W, ACRES 3.91, LOT 1 PM 6899

Address or Location: Lot 1

Geo/Assessors code: 0000055019

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 150 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, J. Mertes RS, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 6/9/2020

Title: Lead Sanitarian

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

L17108KEV


RECEIVED
FEB 15 2008
Montana Department of
Environmental Quality
Water Quality Regional Office

LINCOLN COUNTY, MONTANA
WOLF MEADOWS
(AMENDED LOT 2 OF MOUNT SNOWY VISTA PLAT NO. 6731)
IN THE NE1/4 OF SECTION 11 AND THE NW1/4 OF SECTION 12, TWP. 29 N., R. 31 W., P.M.M.
FOR: DANIEL BRISKIN DATE: JUNE 2007

EQ08-1811

DETAIL OF DITCH
ALONG THE UPPER DITCH LINES OF APPROACH ROADS





NO WELLS OR SEPTICS WITHIN 100' OF PROPERTY BOUNDARIES

LEGEND

- SOILS PROFILE
- PERCOLATION SITE
- PROPOSED WELL SITE
- STORMWATER POND 20'X 30'X 2'
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-100' TRENCHES 10' APART
- REPLACEMENT SITE 3-100' TRENCHES 10' APART
- 200' MIXING ZONE

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
4/18/08
Reviewer EQ# 08-1811 Date

SCALE
1 INCH = 200 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 06/18/07	
DRAWN BY: MDM	FILE:LIBBYCRKSUB.DWG