LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/20/2020 Expiration Date: 07/20/2021

Property Owner: Concord View Homes c/o: John Cordara

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Elmer Brenneman License No. 170

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement __XX__ Extension ____ Other

Describe: 67' Laterals spaced at 7' apart, for total dimension 67'X17' laterals buried at 28"

Parcel Description:

Legal: S09, T36 N, R26 W, C.O.S. 3778, PARCEL D, 20.00 ACRES BROOK HOLLOW SUB.

Address or Location: 653 SINCLAIR LN Eureka, MT 59917

Geo/Assessors code: 0000055528

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 200 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Merles, R.S.

Closure Statement:

I, Elmer Brenneman, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Elmer Brenneman *Date:* 7-23-2020


Title: Brennemans Excavation

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



Base survey provided by Kootenai Surveyors Inc. on October 9, 2019, all wells and drainfields identified within 100-feet of property are shown.