LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/9/2019 Expiration Date: 9/9/2020

Property Owner: Paul Coon c/o:

Address: [redacted]

Telephone: (cell) [redacted] (Work)

Installer: Ketih Mack License No. 111

__ New Installation ____ Existing System

____ Repair __xx__ Replacement ____ Extension ____ Other

Describe: Two 70' Laterals in gravelless chambers

Parcel Description:

Legal: HAYES TRACTS, S23, T30 N, R31 W, LOT 8 IN NESE

Address or Location: 36372 US HWY 2 LIBBY MT 59923

Geo/Assessors code: 0000003533

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size 140 lineal ft

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

NORTH

LOT LAYOUT

70'

Drain Field

1000

REPLACEMENT

CCI