LINCOLN COUNTY
DEPARTMENT of ENVIRONMENTAL HEALTH
Wastewater Treatment and Disposal System
PERMIT

install
Sign & return

Issue Date: 7-25-02 Expiration Date: 7-25-03

Property Owner: JACK AND DEANNA DOYING

Address: C/o Timberline Ready Mix PO Box 882 Eureka, MT 59917

Telephone: (Home)_____ (Work) [redacted]

Installer: Timberline License No. 78

✓ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: Carpenter Lake, Lot 15 S29 T37 R27

Address or Location: Sophie Lake Road

Approved Design Criteria:

Bedrooms 1 or 2 Septic Tank Size: 1000 gallons Drainfield Size: 130 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: _____

Issued By: John Peterson, RS

Closure Statement:

I, Barbara Renkema, have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Barbara Renkema Date: 9-4-02

Title: Inspector

LOT LAYOUT

CARPENTER LAKE
Lot 15

N
No Scale

