LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/26/2020 Expiration Date: 06/26/2021

Property Owner: Randy Edwards c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: License No:

__XX__ New Installation _____Existing System

____ Repair _____Replacement ____ Extension _____Other

Describe: Three 85' Laterals using chambers.

Parcel Description:

Legal: S32, T32 N, R31 W, ACRES 19.756, TR 1 in SWSE

Address or Location: 4916 BOBTAIL RD Libby MT 59923

Geo/Assessors code: 0000002448

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 255 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Charles Riley, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Charles Riley *Date:* 5/26/21

Title: Owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

5

LOT LAYOUT

water
O Well
155' From septic Tank slopes From To septic System Down well

