LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/07/2020 Expiration Date: 07/07/2021

Property Owner: Peter & Tine Hersey c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Bruce Todd License No. 54

XX New Installation ____ Existing System

____ Repair ___ Replacement ____ Extension ____ Other

Describe: Two 50' Laterals

Parcel Description:

Legal: S36, T34 N, R25 W

Address or Location: 678 Sunday Creek Rd Stryker, MT

Geo/Assessors code:

Approved Design Criteria:

Bedrooms 1 Septic Tank Size: 1000 gallon Drainfield Size: 100 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, BRUCE TODD *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Bruce Todd *Date:* 9-29-2020

Title: INSPECTOR

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Lot Layout

Peter and Tina Hersey

