DEPARTMENT of ENVIRONMENTAL HEALTH
Wastewater Treatment and Disposal System
PERMIT

contractor sign & return

Issue Date: 9-8-99 Expiration Date: 9-8-00

Property Owner: GARRY AND BARBRA HOADLEY

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: Bob Epperson License No. 77

✓ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: WILDERNESS PLATEAU BLOCK 4, LOT 3 S19 T31N R33W

Address or Location: BIGHORN WAY

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 220 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: _____

Issued By: Johnny Peterson, RS

Closure Statement:

I, Robert H. Epperson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Robert H. Epperson Date: Oct. 19, 1999

Title: Installer

LOT LAYOUT

WILDERNESS PLATEAU
LOT 3, BLOCK 4

