**LINCOLN COUNTY**
**DEPARTMENT OF ENVIRONMENTAL HEALTH**
**WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 06/25/2020 Expiration Date: 06/25/2021

Property Owner: Robert Horner c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: ~~Quality Excavation~~ Charley Follensbee License No. ~~[redacted]~~ 96

__XX__ New installation ____ Existing System 25% Renew Fee

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Five 92' Laterals using chambers.

*Parcel Description:*

Legal: GUT CREEK, S06, T35 N, R27 W, ACRES 10.001, LOT 3B PM 5467

Address or Location: LOT 3B

Geo/Assessors code: 0000017949

*Approved Design Criteria:*

# Bedrooms 3 Septic Tank Size: 1500 gallons Drainfield Size: 460 lineal feet

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** Jake Mertes, R.S.

Closure Statement: Charley Follensbee *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* [signature] *Date:* 4/19/22

*Title:* A1-Outback Const owner/op

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-283-2442**

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

5/

## LOT LAYOUT

