Licensed Installer
Sign & Return

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/16/03 Expiration Date: 10/17/04

Property Owner: William & Frances Hunsaker c/o:

Address: 13159 North Highway 2 Troy, MT 59935

Telephone: (Home) [redacted] (Work)

Installer: John Kampfe License No. 15

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe:

Parcel Description:

Legal: W-1/2 NE-1/4 SW-1/4 S17 T33 R34

Address or Location: 13159 North Highwy 2

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 500 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: John Kampfe *Date:* 11-14-03

Title: INSTALLER


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
SEPTIC TANK PERMIT
IN STATE LINE MANOR SUBDIVISION
IN SECTION 17 TWP. 33 N., R. 34 W., P.M.M.
FOR: WILLIAM L. HUNSAKER DATE: OCTOBER 2003



LEGEND

- SOILS PROFILE
- PERCOLATION SITE
- EXISTING WELL SITE
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 5-100' TRENCHES 10' APART
- REPLACEMENT SITE 5-100' TRENCHES 10' APART
- 500' MIXING ZONE

SCALE
1 INCH = 200 FT.

DAVIS SURVEYING INC. (406)295-5441	
DATE: OCTOBER 2003	
DRAWN BY: RES	FILE: T3334178