LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/27/2020 Expiration Date: 05/27/2021

Property Owner: Steve Iker c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Self/ Gideon Yutzy Assisting License No. 113

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 84' Laterals using chambers

Parcel Description:

Legal: TOBACCO VALLEY VIEW PM 6898, LOT 18, ACRES 3.881, S23, T36 N, R27 W

Address or Location: Lot 18

Geo/Assessors code: 0000055431

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 252 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Gideon Yutzy, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*


Signed: [signature] *Date:* 9-25-2020

Title: Licensed Installer #113

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER


Property line
80'
1000gallon tank with filter
3 - 24" infiltrator chamber legs 84' long each with 21 chambers per leg
total leach running length 252'
63 infiltrator sections total
5' spacing between each leg of leach field
approximately 24" cover over tank and infiltrators.
90'
~84'
5'
5'
house
Tank
electrical
drive way
well - 120' minimum from leach field
Property line