#07717

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 8/28/2019

Property Owner: Patrick Kearney

Mailing Address: [redacted]

Telephone: (Home) [redacted] (Work)

Name of Person Who Installed System Being Reviewed: Timberline Ready Mix

Type of System Work Reviewed:

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement __xx__ Extension ____ Other

Describe: Three 70' laterals using gravelless chambers.

Property Description:

Legal: S20 T37 R26

Address or Location: COS 4449 784 Pluid Road, Eureka, MT

Reviewed Design Components:

Wastewater Flows: 225 Sewer Lines: sch40 Septic Tank: 1000 Effluent Filter: No

Dosing or Lift Tank: no Drainfield Size: 210 Drainfield Construction: gravelless

Hydraulic Function: yes

Comments:

System Review Documentation Statement:

I, _____, have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.

Signed: _____ *Date:* _____

Title: _____

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.

DISCLAIMER

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

Pat Kearney

S 20 T 37N R 26W

119 A

COS 4449

