# PERMIT

Issue Date: 11-4-96 Expiration Date: 11-4-97

Property Owner: HENRY J. LASALA

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: Oedewaldt Const. License No. 2

✓ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: in the S½ Sec 27. T32N R34W

Address or Location: West of Troy - off Timber Lane

Approved Design Criteria:

# Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 240 lineal feet

**INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.**

Special Instructions: _____

Issued By: John W. Peterson, RS

Closure Statement:

*I, JERRY J. OEDEWALDT, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* _____ *Date:* 11/15/96

*Title:* V.P.

# LOT LAYOUT

## LASALA SEPTIC TANK PERMIT
## OCTOBER 1996

