LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/15/2019 Expiration Date: 11/15/2020

Property Owner: Ralph & Susan Lippert c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Terry Odewaldt License No. 002

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 64' Laterals using gravelless chambers

Parcel Description:

Legal: VAN DYKE HOMESTEAD, S34, T31 N, R33 W, Lot 004, ACRES 7.32, PM 6307

Address or Location: Lot 4

Geo/Assessors code: 0000053751

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 190 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Terry Odewaldt, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 11/24/2019

Title: President

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly

LINCOLN COUNTY MONTANA

LOT LAYOUT:

REVISED LOT 4 OF PLAT NO. 6307
In the NE1/4 of Section 34,
Twp. 31 N., R. 33 W., P.M.M.
For: Ralph N. & Susan M. Lippert
Date: May 2019


LEGEND

- EXISTING BUILDING SITE
- (W) EXISTING WELL SITE
- SLOPE
- NEW SEPTIC SITE MUST COMPLY WITH THE STATE DEQ APPROVAL PER E.Q. #01-1380
- NEW REPLACEMENT SITE MUST COMPLY WITH THE STATE DEQ APPROVAL PER E.Q. #01-1380

NOTES:

NO EXISTING WELLS OR DRAINFIELDS WITHIN 100' OF THE PROPERTY BOUNDARIES OTHER THAN THOSE SHOWN.

STANDARD SEPTIC SYSTEM



Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality

Local Reviewer — Date 5/23/19

Accepted under contract

DEQ Representative — Date

Graphic Scale:

200 0 100 200

1 inch = 200 ft.

CABINET MOUNTAIN SURVEYING, LLC
TROY, MT 59935

DATE: 05/15/19	Land Projects 2019

RALPH & SUSAN LIPPERT
11/23/2019

