County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/22/2019 Expiration Date: 8/22/2020

Property Owner: John Mast c/o: Tom Cole

Address:

Telephone: (Home) [redacted] (Work)

Installer: Tom Cole License No. 1

___ New Installation ___xx___ Existing System

____ Repair ___xx___ Replacement ____ Extension ____ Other

Describe: Installing new three ring drywell to replace failed drywell.

Parcel Description:

Legal: S10 T30 R31

Address or Location: Reed-Way Block 1 Lot 5&6

Geo/Assessors code: 0000003619

Approved Design Criteria:

300 GPD Septic Tank Size: 1000 gallons Drainfield Size: 3 ring Drywell

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Thomas J Cole *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 8-24-19


Title: owner/operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


N
SaveRite
Soil down 5' gravel Rock Sand
old dry well
well
New 500 gal drywell
Hwy 2 South