LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/21/2020 Expiration Date: 04/21/2021

Property Owner: George Mercer c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Brian Anderson License No. 175

_xx_ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Explain: Single Family Home

Describe: Four 84' laterals using gravelless chambers. Size reduced per 0.4 app rate

Parcel Description:

Legal: S34 T30 R31 Tract 2A1

Address or Location: Willow Road

Geo/Assessors code: 0000002809

Approved Design Criteria:

Bedrooms 3 Septic Tank Size 1000 gallons Drainfield Size: 338 linear feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Brian Anderson *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 11/18/20

Title: Owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

⊗ Well location

LOT LAYOUT