LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/27/2020 Expiration Date: 05/27/2021

Property Owner: Steve Motsco c/o:

Address: [redacted]

Telephone: [redacted] Home) (Work) [redacted]

Installer: Koocanusa Excavating LLC License No. 135

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Revision of 10/24/2008 permit. Four 88' Pressure dosed laterals using chambers

Parcel Description:

Legal: KSANKA FOOTHILLS, S10, T36 N, R26 W, ACRES 20, LOT 3 PM 6655

Address or Location: Lot 3

Geo/Assessors code: 0000054643

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500/500 gallons Drainfield Size: (4)-88' lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Buck Schermerhorn, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 8/4/20

Title: President

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



STEVE MOTSCO SITE LAYOUT

LOT 3, KSANKA FOOTHILLS
S10 T36N R26W, 734 KSANKA FOOTHILLS ROAD
EUREKA, MT 59917

REV	DATE	COMPANY: KEI	SCALE: 1/16 = 1'-0"	DRAWING SIZE: 24" x 36"	KOOCANUSA EXCAVATING MOTSCO SEPTIC		
		CONTRACT: VERBAL	DATE: 2/2020	DIM TOLERANCES: .xx ±0.02 .xxx ±0.005	SITE LAYOUT		
		PLOT FILE: PML-0001	WEIGHT: ----	FINISH:	SCHEMATIC/WORKING	S. MCNAMARA	2/25/20
					DRAWING NO: 1913-001		2/25/20
							1

THIS DRAWING IS PROPERTY OF KEI UNTIL CONTRACT HAS BEEN SECURED BETWEEN OWNER & KEI IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM KEI MANAGEMENT