LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/17/2020 Expiration Date: 06/17/2021

Property Owner: Steven & Daniel Nelson c/o: Webb Construction Inc.

Address: [redacted]

Telephone: [redacted] (Work) [redacted]

Installer: Tracy Webb License No. 89

__XX__ New Installation _____Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Infiltration Lines 4X92'

Parcel Description:

Legal: S29, T36 N, R26 W, C.O.S. 393, ACRES 19.89, TR-6B IN S2NWNE

Address or Location: 991 S ROLLING HILLS RD Eureka MT 59917

Geo/Assessors code: 0000007036

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 368 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Tracy Webb, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Tracy Webb *Date:* 3-31-21

Title: Installer 89

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

6-11-20 Steven & Daniel Nelson 991 S. Rolling Hills Rd. Eureka 36N 26W - 29

